

Senior Geologist  
Ground Water Survey & Development Agency, Solapur  
Ground Floor New Central Administrative Building  
Collector Office Campus, Solapur 413003

State of Maharashtra  
Water Supply and Sanitation Department

Phone No. (0217) 2725875  
E Mail spr\_gsa@yahoo.co.in



To,  
Shivratna School  
(Aff.No.1130956) Yashvantnagar, Akluj  
Tal.malshiras, Solapur .

SDL/Akluj/Che/ 19 /2022  
Date- 16/2/2020

Chemical Water Analysis Report Sub Divisional Laboratory Akluj

SR. NO.	Taluka	Village	Source BW/DW	Station code	Location	Lab Ref	Date of collection	Date of Analysis	Colour	Odour	PH	E.C. $\mu\text{mh/cm}$	TDS mg/L	Tur NTU	TH mg/L	Fe mg/L	TA mg/L	Cl mg/L	SO <sub>4</sub> mg/L	F mg/L	NO <sub>3</sub> mg/L
1	Malshiras	Yashvantnagar	Bore	-	Shivratna School	ACP007	10-02-2022	16-02-2022	Colourless	Odourless	7.5	78.2	50	0.5	15	0	20	20	0	0	2.0
									<b>BIS (10500---2004-05) Highest</b>		6.5-8.5	-	500	--	300	0.3	200	250	200	1	45
									<b>BIS (10500---2004-05) Max. Permissible Limit</b>		>8.5		2000	>10	600	No Relaxion	600	1000	400	1.5	No Relaxion

Cond -Electrical Conductivity , T.D.S. -Total Dissolved Solids, Turb -Turbidity,

Fe - Iron, T\_ Alk - Total Alkalinity, Cl - Chloride, F- Fluoride, SO<sub>4</sub> - Sulphate, NO<sub>3</sub> - Nitrate.

This report is restricted only for the Sample/s is Submitted to this Laboratory.

This Sample/s is/are not Collected by this Laboratory

  
Senior Geologist  
Ground Water Survey & Development Agency  
Solapur




Phone No. (0217) 2725875  
E Mail spr\_gsda@yahoo.co.in

State of Maharashtra  
Water Supply and Sanitation Department  
Ground Water Survey & Development Agency, Solapur  
Sub Divisional Laboratory Akluj  
Bacteriological Water Analysis Report

To,	Shivratna school, (Aff.No.1130956 ) Yashvantnagar, Akluj , Tal.Malshiras, Solapur				
Reciept No.Date	:- 10/02/2022				
Lab Reference ID	:- AB08				
Date of collection	:- 10/02/2022				
Date of sample recived	:- 10/02/2022				
Date of Analysis	:- 14/02/2022				
Sr.No.	Sample Details	Testing Results			Remark
		Bacteria No. Per 100 ml water sample			
		Total coliforms	Thermotolerant coliforms	E.Coli	
8	Shivratna school, (Aff.No.1130956 ) Bore Yashvantnagar	0	0	0	Water is Potable (Fit)
Remark: If the water sample is nonpotable ( unfit) ,sample must be rechecked after chlorination. After that It is potable then only one use it for Drinking.					
Outward No :- 19/22			date : 16/02/2022		
Remark informed bymail/Telephone Date:- - 16/02/2022					

This report is restricted only for the Sample/s is Submitted to this Laboratory.  
This Sample/s is/are not Collected by this Laboratory

  
Senior Geologist  
Ground Water Survey & Development Agency  
Solapur